

# CERTIFICATE

## (1) EC-Type Examination

(2) **Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC**

(3) EC-Type Examination Certificate Number: **KEMA 99ATEX0518 X** Issue Number: **6**

(4) Equipment: **Guided Wave Radar Level Transmitter Eclipse Model 705-5...-A.. and Model 705-5...-B.. and Probe Eclipse Model 7E.-..... and Model 7M.-.....**

(5) Manufacturer: **Magnetrol International N.V.**

(6) Address: **Heikensstraat 6, 9240 Zele, Belgium**

(7) This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., notified body number 0344 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the directive.

The examination and test results are recorded in confidential test report number NL/KEM/ExTR06.0017/\*\*.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0 : 2009**  
**EN 60079-27 : 2008**

**EN 60079-11 : 2007**  
**EN 61241-11 : 2006**

**EN 60079-26 : 2007**

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-Type Examination Certificate relates only to the design, examination and tests of the specified equipment according to the Directive 94/9/EC. Further requirements of the directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the equipment shall include the following:



**II 1 G Ex ia IIC T4 Ga**  
**II 1 D Ex ia IIIC T100 °C Da IP6X**

This certificate is issued on 5 June 2014 and, as far as applicable, shall be revised before the date of cessation of presumption of conformity of (one of) the standards mentioned above as communicated in the Official Journal of the European Union.

DEKRA Certification B.V.

R. Schuller  
Certification Manager

Page 1/3



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EC-Type Examination Certificate KEMA 99ATEX0518 X**

Issue No. 6

(15) **Description**

Guided Wave Radar Level Transmitter Eclipse Model 705-5...-A.. and Model 705-5...-B.. and Probe Eclipse Model 7E.-....-... and Model 7M.-....-... are used for level detection. Using the Time Domain Reflectometry and Micro Power Impulse Radar Technology, a fluid level is converted into a 4 - 20 mA current with Hart signal or a digital fieldbus signal.  
The maximum probe length is 36 m.

The transmitter enclosure provides a degree of protection IP66 as per EN 60529.

Ambient temperature range -40 °C to +70 °C.

The maximum temperature of the enclosure T100 °C is referred to an ambient temperature of 70 °C and is applicable for a maximum dust layer thickness of 5 mm.

**Electrical data**

Level Transmitter Eclipse Model 705-51...-....:

Output/supply circuit (terminals + and -):

in type of protection intrinsic safety Ex ia IIC or Ex ia IIIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$U_i = 28,4 \text{ V}$ ;  $I_i = 124 \text{ mA}$ ;  $P_i = 0,84 \text{ W}$ ;  $C_i = 2,2 \text{ nF}$ ;  $L_i = 3 \text{ }\mu\text{H}$ .

Level Transmitter Eclipse Model 705-52...-.... and Model 705-53...-....:

Output/supply circuit (terminals + and -):

in type of protection intrinsic safety Ex ia IIC or Ex ia IIIC, suitable for connection to a FISCO fieldbus system in accordance with EN 60079-27, with the following maximum values:

$U_i = 17,5 \text{ V}$ ;  $I_i = 380 \text{ mA}$ ;  $P_i = 5,32 \text{ W}$ ;  $C_i = 3 \text{ nF}$ ;  $L_i = 3 \text{ }\mu\text{H}$ .

or

in type of protection intrinsic safety Ex ia IIC or Ex ia IIIC, only for connection to a certified intrinsically safe circuit, with the following maximum values:

$U_i = 28,4 \text{ V}$ ;  $I_i = 124 \text{ mA}$ ;  $P_i = 0,84 \text{ W}$ ;  $C_i = 3 \text{ nF}$ ;  $L_i = 3 \text{ }\mu\text{H}$ .

**Installation instructions**

In type of protection Ex ia IIIC, when the temperature under rated conditions, is higher than 70 °C at the cable or conduit entry point, or 80 °C at the branching point of the conductors, suitable heat resistant cables and cable entries shall be used.

(16) **Test Report**

NL/KEM/ExTR06.0017/\*\*.

(13) **SCHEDULE**

(14) **to EC-Type Examination Certificate KEMA 99ATEX0518 X**

Issue No. **6**

(17) **Special conditions for safe use**

Because the enclosure of the Guided Wave Radar Level Transmitter Eclipse Model 705-5...-1. and 705-5...-7. and/or Probe Eclipse Model 7...-...-... is made of aluminium, if it is mounted in an area where the use of category 1 G apparatus is required, it must be installed such, that, even in the event of rare incidents, ignition sources due to impact and friction sparks are excluded.

For applications in explosive atmospheres caused by combustible dust, gases, vapours or mists and where category 1G or 1D apparatus is required, electrostatic charges on the non-metallic parts of the Probe Eclipse Model 7M5-...-..., Model 7M7-...-... and Model 7.F-...-... shall be avoided.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report NL/KEM/ExTR06.0017/\*\*.