



Certificate of Compliance

Certificate: 1282824

Master Contract: 155560

Project: 2688426

Date Issued: March 18, 2014

Issued to: Rosemount Analytical Inc.

Uniloc Division
2400 Barranca Pky
Irvine, CA 92606
USA
Attention: Dana Crowley

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Blake Williams

Issued by: Blake Williams

PRODUCTS

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

CLASS – 2258 03 – PROCESS CONTROL EQUIPMENT – Intrinsically Safe and Non-Incendive Systems – For Hazardous Locations

Exia Intrinsically Safe

Class I Division 1 Groups A, B, C, D T4

Ex ia IIC T4

IRC Infrared Remote Control, battery operated hand held remote control unit. Intrinsically safe when powered by two 1.5 V AAA size batteries of models Energizer E92, Energizer EN92, Duracell MN2400, or Duracell PC2400. Operating ambient temperature rating: $-20^{\circ}\text{C} < T_{\text{amb}} < +50^{\circ}\text{C}$



Certificate: 1282824

Master Contract: 155560

Project: 2688426

Date Issued: March 18, 2014

CLASS – 2258 83 – PROCESS CONTROL EQUIPMENT – Intrinsically Safe and Non-Incendive Systems – For Hazardous Locations – Certified to US Standards

Exia Intrinsically Safe

Class I Division 1 Groups A, B, C, D T4

Class I Zone 0 AEx ia IIC T4

IRC Infrared Remote Control, battery operated hand held remote control unit. Intrinsically safe when powered by two 1.5 V AAA size batteries of models Energizer E92, Energizer EN92, Duracell MN2400, or Duracell PC2400. Operating ambient temperature rating: $-20^{\circ}\text{C} < T_{\text{amb}} < +50^{\circ}\text{C}$

APPLICABLE REQUIREMENTS

CSA C22.2 No 0-10 - General Requirements - Canadian Electrical Code Part II

CSA C22.2 No. 142-M1987 (R2009) - Process Control Equipment

CSA C22.2 No 157-M1992 (R2012) - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations.

CSA C22.2 No 60079-0:11 - Electrical apparatus for explosive gas atmospheres. - PART 0: General Requirements

CSA C22.2 No 60079-11:11 - Electrical apparatus for explosive gas atmospheres. - PART 11: Intrinsic Safety "i"

UL Standard 508, Seventeenth Edition - Electric Industrial Control Equipment

UL 913, Eighth Edition - Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II, III, Division 1, Hazardous (Classified) Locations.

UL 60079-0 Sixth Edition - Electrical apparatus for explosive gas atmospheres. - PART 0: General Requirements.

UL 60079-11 Sixth Edition - Electrical apparatus for explosive gas atmospheres. - PART 11: Intrinsic Safety "i"