



Failure Modes, Effects and Diagnostic Analysis

Project:

Emerson's Rosemount®
3051S Advanced HART Diagnostics Pressure Transmitter,
option code DA2
Sensor Software revision 7 or 8

Company:

Rosemount, Inc.
Shakopee, MN
USA

Contract Number: Q15/10-010

Report No.: ROS 08/11-17 R002

Version V2, Revision R3, October 14, 2016

Ted Stewart



Management Summary

This report summarizes the results of the hardware assessment in the form of a Failure Modes, Effects, and Diagnostic Analysis (FMEDA) of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, Sensor Software Revision 7 or 8. A Failure Modes, Effects, and Diagnostic Analysis is one of the steps to be taken to achieve functional safety certification per IEC 61508 of a device. From the FMEDA, failure rates are determined. The FMEDA that is described in this report concerns only the hardware of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter. For full functional safety certification purposes all requirements of IEC 61508 must be considered.

The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter is a two-wire 4 – 20 mA smart device. It contains self-diagnostics and is programmed to send its output to a specified failure state, either high or low upon internal detection of a failure. For safety instrumented systems usage, it is assumed that the 4 – 20 mA output is used as the primary safety variable.

Below list the versions of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter that have been considered in the hardware assessment:

- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter Coplanar Differential & Coplanar Gage; Sensor Software Revision 7 or 8
- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter Coplanar Absolute, In-line Gage, & In-line Absolute; Sensor Software Revision 7 or 8

The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter is classified as a Type B¹ element according to IEC 61508, having a hardware fault tolerance of 0.

The failure rate data used for this analysis meets the *exida* criteria for Route 2_H. (See Section 5.3). Therefore, the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter meets the hardware architectural constraints for up to up to SIL 2 at HFT=0 (or SIL 3 @ HFT=1) as a single device when the listed failure rates are used. If Route 2_H is not applicable for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, the architectural constraints will need to be evaluated per Route 1_H.

The analysis shows that the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter has a Safe Failure Fraction greater than 90% (assuming that the logic solver is programmed to detect over-scale and under-scale currents) and therefore meets hardware architectural constraints for up to SIL 2.

The failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter are listed in Table 1.

¹Type B element: “Complex” element (using micro controllers or programmable logic); for details see 7.4.4.1.3 of IEC 61508-2, ed2, 2010.



Table 1 Failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, Coplanar Differential & Coplanar Gage

Failure Category	Failure Rate (FIT) – PATC Diagnostics Not Enabled	Failure Rate (FIT) – PATC Diagnostics Enabled
Fail Safe Undetected	6.2	6.2
Fail Dangerous Detected	685.2	698.7
Fail Detected (detected by internal diagnostics)	612.7	626.2
Fail High (detected by logic solver)	21.6	21.6
Fail Low (detected by logic solver)	50.9	50.9
Fail Dangerous Undetected	33.7	20.2
No Effect	203.6	203.6
Annunciation Undetected	30.4	30.4

Note: PATC – Power Advisory and Transmitter Power Consumption

Table 2 Failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, Coplanar Absolute, In-line Gage & In-line Absolute

Failure Category	Failure Rate (FIT) – PATC Diagnostics Not Enabled	Failure Rate (FIT) – PATC Diagnostics Enabled
Fail Safe Undetected	6.2	6.2
Fail Dangerous Detected	681.2	694.8
Fail Detected (detected by internal diagnostics)	608.7	622.3
Fail High (detected by logic solver)	21.6	21.6
Fail Low (detected by logic solver)	50.9	50.9
Fail Dangerous Undetected	33.9	20.3
No Effect	188.6	188.6
Annunciation Undetected	32.3	32.3

These failure rates are valid for the useful lifetime of the product, see Appendix A.

The failure rates listed in this report do not include failures due to wear-out of any components. They reflect random failures and include failures due to external events, such as unexpected use, see section 4.2.2.

Table 3 lists the failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter according to IEC 61508, ed2, 2010.



Table 3 Failure rates according to IEC 61508 in FIT

3051S Advanced Diagnostics Pressure Transmitter, Sensor Revision 7 or 8	λ_{SD}	λ_{SU}^2	λ_{DD}	λ_{DU}	SFF ³
Coplanar Differential & Coplanar Gage	-	6	685	34	95%
Coplanar Absolute, In-line Gage, & In-Line Absolute	-	6	681	34	95%
Coplanar Differential & Coplanar Gage PATC	-	6	699	20	97%
Coplanar Absolute, In-line Gage, & In-Line Absolute PATC	-	6	695	20	97%

3051S Advanced Flowmeter based on 1195, 405, or 485 Primaries

3051S Advanced HART Flowmeter Series ⁴ , Sensor sw revision 7 or 8	-	14	685	45
---	---	----	-----	----

Rosemount 3051S Advanced Level Transmitter: (w/o additional Seal)

3051S Advanced HART Level Transmitter, Sensor sw revision 7 or 8	-	6	702	51
--	---	---	-----	----

3051S Advanced Transmitter with Remote Seals⁵

A user of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter can utilize these failure rates in a probabilistic model of a safety instrumented function (SIF) to determine suitability in part for safety instrumented system (SIS) usage in a particular safety integrity level (SIL). A full table of failure rates is presented in section 4.4 along with all assumptions.

² It is important to realize that the No Effect failures are no longer included in the Safe Undetected failure category according to IEC 61508, ed2, 2010.

³SFF not required for devices certified using Route 2_H data. For information detailing the Route 2_H approach as defined by IEC 61508-2, see Technical Document entitled "Route 2_H SIL Verification for Rosemount Type B Transmitters with Type A Components".

⁴ Refer to ROS 13/04-008 R001 V1R0 for the Flowmeter FMEDA report for models that are excluded.

⁵ Refer to the Remote Seal (ROS 1105075 R001 V2R1) FMEDA report for the additional failure rates to use when using with attached Remote Seals, or use exSILentia.



Table of Contents

Management Summary	2
1 Purpose and Scope	7
2 Project Management	8
2.1 <i>exida</i>	8
2.2 Roles of the parties involved.....	8
2.3 Standards and literature used.....	8
2.4 Reference documents	9
2.4.1 Documentation provided by Rosemount, Inc.	9
2.4.2 Documentation generated by <i>exida</i>	9
3 Product Description	10
4 Failure Modes, Effects, and Diagnostic Analysis.....	11
4.1 Failure categories description.....	11
4.2 Methodology – FMEDA, failure rates	12
4.2.1 FMEDA	12
4.2.2 Failure rates	12
4.3 Assumptions.....	13
4.4 Results	14
5 Using the FMEDA Results.....	16
5.1 Impulse line clogging	16
5.2 PFD _{AVG} calculation Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter 16	
5.3 <i>exida</i> Route 2 _H Criteria.....	16
6 Terms and Definitions.....	18
7 Status of the Document	19
7.1 Liability	19
7.2 Releases	19
7.3 Future enhancements.....	20
7.4 Release signatures.....	20
Appendix A Lifetime of Critical Components.....	21
Appendix B Proof Tests to Reveal Dangerous Undetected Faults	22
B.1 Partial Proof Test – PATC Diagnostics Not Enabled.....	22
B.2 Comprehensive Proof Test – PATC Diagnostics Not Enabled	23
B.3 Partial Proof Test – PATC Diagnostics Enabled	24
B.4 Proof Test Coverage	24
Appendix C <i>exida</i> Environmental Profiles	25
Appendix D Determining Safety Integrity Level.....	26





1 Purpose and Scope

This document shall describe the results of the hardware assessment in the form of the Failure Modes, Effects and Diagnostic Analysis carried out on the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter. From this, failure rates and example PFD_{AVG} values may be calculated.

The information in this report can be used to evaluate whether an element meets the average Probability of Failure on Demand (PFD_{AVG}) requirements and if applicable, the architectural constraints / minimum hardware fault tolerance requirements per IEC 61508 / IEC 61511.

An FMEDA is part of the effort needed to achieve full certification per IEC 61508 or other relevant functional safety standard.



2 Project Management

2.1 *exida*

exida is one of the world’s leading accredited Certification Bodies and knowledge companies specializing in automation system safety and availability with over 300 years of cumulative experience in functional safety. Founded by several of the world’s top reliability and safety experts from assessment organizations and manufacturers, *exida* is a global company with offices around the world. *exida* offers training, coaching, project oriented system consulting services, safety lifecycle engineering tools, detailed product assurance, cyber-security and functional safety certification, and a collection of on-line safety and reliability resources. *exida* maintains the largest process equipment database of failure rates and failure modes with over 100 billion unit operating hours.

2.2 Roles of the parties involved

Rosemount, Inc. Manufacturer of the Rosemount 3051S DA2

exida Performed the hardware assessment

Rosemount, Inc. contracted *exida* with the hardware assessment of the above-mentioned element.

2.3 Standards and literature used

The services delivered by *exida* were performed based on the following standards / literature.

[N1]	IEC 61508-2: ed2, 2010	Functional Safety of Electrical/Electronic/Programmable Electronic Safety-Related Systems
[N2]	Electrical Component Reliability Handbook, 3rd Edition, 2012	<i>exida</i> LLC, Electrical Component Reliability Handbook, Third Edition, 2012, ISBN 978-1-934977-04-0
[N3]	Mechanical Component Reliability Handbook, 3rd Edition, 2012	<i>exida</i> LLC, Electrical & Mechanical Component Reliability Handbook, Third Edition, 2012, ISBN 978-1-934977-05-7
[N4]	Safety Equipment Reliability Handbook, 3rd Edition, 2007	<i>exida</i> LLC, Safety Equipment Reliability Handbook, Third Edition, 2007, ISBN 978-0-9727234-9-7
[N5]	Goble, W.M. 2010	Control Systems Safety Evaluation and Reliability, 3 rd edition, ISA, ISBN 97B-1-934394-80-9. Reference on FMEDA methods
[N6]	IEC 60654-1:1993-02, second edition	Industrial-process measurement and control equipment – Operating conditions – Part 1: Climatic condition
[N7]	O’Brien, C. & Bredemeyer, L., 2009	<i>exida</i> LLC., Final Elements & the IEC 61508 and IEC Functional Safety Standards, 2009, ISBN 978-1-9934977-01-9



[N8]	Scaling the Three Barriers, Recorded Web Seminar, June 2013,	Scaling the Three Barriers, Recorded Web Seminar, June 2013, http://www.exida.com/Webinars/Recordings/SIF-Verification-Scaling-the-Three-Barriers
[N9]	Meeting Architecture Constraints in SIF Design, Recorded Web Seminar, March 2013	http://www.exida.com/Webinars/Recordings/Meeting-Architecture-Constraints-in-SIF-Design

2.4 Reference documents

2.4.1 Documentation provided by Rosemount, Inc.

[D1]	3051S_hdpt_sirs.doc	Safety Integrity Requirements Specification, 3051S HART Diagnostics Pressure Transmitter Phase 2, Revision C
[D2]	3051S_hdpt_srs.doc	Software Requirements Specification, 3051S Advanced HART Diagnostic Pressure Transmitter Coplanar Differential & Coplanar Gage Phase 2, Revision H
[D3]	03151-3610AC.pdf	Schematic, Feature Bd, HART Diagnostic, Drawing No. 03151-3610-0001, Rev. AC
[D4]	03151-4214 transient Terminal Block.pdf	Schematic, Transient Terminal Block, Drawing No. 03051-4214, Rev. AB
[D5]	03151-4211 standard Terminal Block.pdf	Schematic, Terminal Block – Standard, Drawing No. 03051-4211, Rev. AB

2.4.2 Documentation generated by *exida*

[R1]	Rosemount Phase 2 HART Diagnostic Feature Board 05262010.efm	Failure Modes, Effects, and Diagnostic Analysis – Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter
[R2]	CAN Mode SM Coplanar II 3051S ROM 6_7.xls	Failure Modes, Effects, and Diagnostic Analysis – Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter
[R3]	CAN Mode SM In-Line 3051T ROM6_7.xls	Failure Modes, Effects, and Diagnostic Analysis – Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter
[R4]	Summary Sheet - Phase 2 3051S Advanced HART Diagnostic Pressure Transmitter Coplanar Differential & Coplanar Gage 05262010.xls	Failure Modes, Effects, and Diagnostic Analysis - Summary – Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter



3 Product Description

The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter is a two-wire 4 – 20 mA smart device used in multiple industries for both control and safety applications. The transmitter consists of a standard well proven Rosemount Supermodule in combination with a Hart Diagnostic Pressure Transmitter (HDPT) Feature Board that performs advanced process diagnostics. It is programmed to send its output to a specified failure state, either high or low, upon internal detection of a failure.

For safety instrumented systems usage it is assumed that the 4 – 20 mA output is used as the primary safety variable. No other output variants are covered by this report.

The FMEDA has been performed for four different configurations of the 3051S Pressure Transmitter, i.e. Coplanar, In-Line, Level, and Flow configurations. The Rosemount 3051S Pressure Transmitter series include the following measurement configurations:

- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter: Coplanar Differential and Gage Coplanar
Capacitance technology is utilized for differential Coplanar measurements.
- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter: Coplanar Absolute, In-Line Gage and In-Line Absolute
Piezoresistive sensor technology is used for the absolute Coplanar and In-Line measurements.
- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter Level
A Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter is available as a Level assembly. The Rosemount Pressure Transmitter Level can be used to measure level on virtually any liquid level vessel. Rosemount 3051S transmitters and seal systems are designed to offer a flexible solution to meet the performance, reliability, and installation needs of nearly any level measurement application.
- Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter Flowmeter
A Rosemount Pressure Transmitter can be combined with primary elements to offer fully assembled flowmeters. The direct mount flowmeter capability eliminates troublesome impulse lines associated with traditional installations. With multiple primary element technologies available, Rosemount flowmeters offer a flexible solution to meet the performance, reliability, and installation needs of nearly any flow measurement application. The flowmeters covered for this assessment are based on the Rosemount 1195, 405, and 485 primary elements. Excluded from the assessment are models with Flo-Tap, remote mount, or temperature input options.

Devices used in safety applications with ambient temperatures below -40F (-40C) but does not exceed -76F(-60C) requires options BR5 (-50C) or BR6 (-60C) and QT.

The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter is classified as a Type B⁶ device according to IEC 61508, having a hardware fault tolerance of 0.

The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter can be connected to the process using an impulse line, depending on the application the clogging of the impulse line needs to be accounted for, see section 5.1.

⁶ Type B element: "Complex" element (using micro controllers or programmable logic); for details see 7.4.4.1.3 of IEC 61508-2, ed2, 2010.



4 Failure Modes, Effects, and Diagnostic Analysis

The Failure Modes, Effects, and Diagnostic Analysis was performed based on the documentation obtained from Rosemount, Inc. and is documented in 2.4.2.

When the effect of a certain failure mode could not be analyzed theoretically, the failure modes were introduced on component level and the effects of these failure modes were examined on system level. This resulted in failures that can be classified according to the following failure categories.

4.1 Failure categories description

In order to judge the failure behavior of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, the following definitions for the failure of the device were considered.

Fail-Safe State	Failure that deviates the process signal or the actual output by more than 2% of span (5% for Flowmeters), drifts toward the user defined threshold (Trip Point) and that leaves the output within active scale.
Fail Safe	Failure that causes the device to go to the defined fail-safe state without a demand from the process.
Fail Dangerous	Failure that deviates the process signal or the actual output by more than 2% of span (5% for Flowmeters), drifts away from the user defined threshold (Trip Point) and that leaves the output within active scale.
Fail Dangerous Undetected	Failure that is dangerous and that is not being diagnosed by automatic diagnostics.
Fail Dangerous Detected	Failure that is dangerous but is detected by automatic diagnostics.
Fail High	Failure that causes the output signal to go to the over-range or high alarm output current (> 21 mA).
Fail Low	Failure that causes the output signal to go to the under-range or low alarm output current (< 3.6 mA).
No Effect	Failure of a component that is part of the safety function but that has no effect on the safety function.
Annunciation Undetected	Failure that does not directly impact safety but does impact the ability to detect a future fault (such as a fault in a diagnostic circuit) and that is not detected by internal diagnostics.
External Leakage	Failure that causes process fluids to leak outside of the valve; External Leakage is not considered part of the safety function and therefore this failure rate is not included in the Safe Failure Fraction calculation.

The failure categories listed above expand on the categories listed in IEC 61508 which are only safe and dangerous, both detected and undetected. In IEC 61508, Edition 2010, the No Effect failures cannot contribute to the failure rate of the safety function. Therefore, they are not used for the Safe Failure Fraction calculation needed when Route 2_H failure data is not available.



Depending on the application, a Fail High or a Fail Low failure can either be safe or dangerous and may be detected or undetected depending on the programming of the logic solver. Consequently, during a Safety Integrity Level (SIL) verification assessment the Fail High and Fail Low failure categories need to be classified as safe or dangerous, detected or undetected.

The Annunciation failures are provided for those who wish to do reliability modeling more detailed than required by IEC61508. It is assumed that the probability model will correctly account for the Annunciation failures. Otherwise the Annunciation Undetected failures have to be classified as Dangerous Undetected failures according to IEC 61508 (worst-case assumption).

External leakage failure rates do not directly contribute to the reliability of a component but should be reviewed for secondary safety and environmental issues.

4.2 Methodology – FMEDA, failure rates

4.2.1 FMEDA

A Failure Modes and Effects Analysis (FMEA) is a systematic way to identify and evaluate the effects of different component failure modes, to determine what could eliminate or reduce the chance of failure, and to document the system in consideration.

An FMEDA (Failure Mode Effect and Diagnostic Analysis) is an FMEA extension. It combines standard FMEA techniques with the extension to identify automatic diagnostic techniques and the failure modes relevant to safety instrumented system design. It is a technique recommended to generate failure rates for each important category (safe detected, safe undetected, dangerous detected, dangerous undetected, fail high, fail low, etc.) in the safety models. The format for the FMEDA is an extension of the standard FMEA format from MIL STD 1629A, Failure Modes and Effects Analysis.

4.2.2 Failure rates

The failure rate data used by *exida* in this FMEDA is from the Electrical and Mechanical Component Reliability Handbooks [N2] and [N3] which was derived using over 100 billion unit operational hours of field failure data from multiple sources and failure data from various databases. The rates were chosen in a way that is appropriate for safety integrity level verification calculations. The rates were chosen to match *exida* Profile 2, see Appendix C. The *exida* profile chosen was judged to be the best fit for the product and application information submitted by Rosemount, Inc.. It is expected that the actual number of field failures due to random events will be less than the number predicted by these failure rates.

For hardware assessment according to IEC 61508 only random equipment failures are of interest. It is assumed that the equipment has been properly selected for the application and is adequately commissioned such that early life failures (infant mortality) may be excluded from the analysis.

Failures caused by external events should be considered as random failures. Examples of such failures are loss of power, physical abuse, or problems due to intermittent instrument air quality.

The assumption is also made that the equipment is maintained per the requirements of IEC 61508 or IEC 61511 and therefore a preventative maintenance program is in place to replace equipment before the end of its “useful life”. Corrosion, erosion, coil burnout etc. are considered age related wearout failures, provided that materials and technologies applied are indeed suitable for the application, in all modes of operation.



The user of these numbers is responsible for determining their applicability to any particular environment. *exida* Environmental Profiles listing expected stress levels can be found in Appendix C. Some industrial plant sites have high levels of stress. Under those conditions the failure rate data is adjusted to a higher value to account for the specific conditions of the plant.

Accurate plant specific data may be used for this purpose. If a user has data collected from a good proof test reporting system such as *exida* SILStat™ that indicates higher failure rates, the higher numbers shall be used.

4.3 Assumptions

The following assumptions have been made during the Failure Modes, Effects, and Diagnostic Analysis of the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter.

- Only a single component failure will fail the entire Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter.
- Failure rates are constant; wear-out mechanisms are not included.
- Propagation of failures is not relevant.
- All components that are not part of the safety function and cannot influence the safety function (feedback immune) are excluded.
- Failures caused by operational errors are site specific and therefore are not included.
- The stress levels are average for an industrial environment and can be compared to the *exida* Profile 2 with temperature limits within the manufacturer's rating. Other environmental characteristics are assumed to be within manufacturer's rating.
- Practical fault insertion tests can demonstrate the correctness of the failure effects assumed during the FMEDA and the diagnostic coverage provided by the automatic diagnostics.
- The HART protocol is only used for setup, calibration, and diagnostics purposes, not for safety critical operation.
- The application program in the safety logic solver is configured to detect under-range (Fail Low) and over-range (Fail High) failures and does not automatically trip on these failures; therefore, these failures have been classified as dangerous detected failures.
- Materials are compatible with process conditions.
- The device is installed per manufacturer's instructions.
- External power supply failure rates are not included.



4.4 Results

Using reliability data extracted from the *exida* Electrical and Mechanical Component Reliability Handbook the following failure rates resulted from the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter FMEDA.

Table 4 Failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, Coplanar Differential & Coplanar Gage

Failure Category	Failure Rate (FIT) – PATC Diagnostics Not Enabled		Failure Rate (FIT) – PATC Diagnostics Enabled	
Fail Safe Undetected	6.2		6.2	
Fail Dangerous Detected	685.2		698.7	
Fail Detected (detected by internal diagnostics)	612.7		612.7	
Fail High (detected by logic solver)	21.6		21.6	
Fail Low (detected by logic solver)	50.9		50.9	
Fail Dangerous Undetected	33.7		20.2	
No Effect	203.6		203.6	
Annunciation Undetected	30.4		30.4	

Table 5 Failure rates for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, Coplanar Absolute, In-line Gage & In-line Absolute

Failure Category	Failure Rate (FIT) – PATC Diagnostics Not Enabled		Failure Rate (FIT) – PATC Diagnostics Enabled	
Fail Safe Undetected	6.2		6.2	
Fail Dangerous Detected	681.2		694.8	
Fail Detected (detected by internal diagnostics)	608.7		608.7	
Fail High (detected by logic solver)	21.6		21.6	
Fail Low (detected by logic solver)	50.9		50.9	
Fail Dangerous Undetected	33.9		20.3	
No Effect	188.6		188.6	
Annunciation Undetected	32.3		32.3	

These failure rates are valid for the useful lifetime of the product, see Appendix A.



According to IEC 61508 the architectural constraints of an element must be determined. This can be done by following the 1_H approach according to 7.4.4.2 of IEC 61508 or the 2_H approach according to 7.4.4.3 of IEC 61508 (See Section 5.3).

The 1_H approach involves calculating the Safe Failure Fraction for the entire element.

The 2_H approach involves assessment of the reliability data for the entire element according to 7.4.4.3.3 of IEC 61508.

The failure rate data used for this analysis meets the *exida* criteria for Route 2_H. Therefore the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter meets the hardware architectural constraints for up to SIL 2 at HFT=0 (or SIL 3 @ HFT=1) when the listed failure rates are used.

If Route 2_H is not applicable for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter, the architectural constraints will need to be evaluated per Route 1_H.

Table 6 Failure rates according to IEC 61508 in FIT

3051S Advanced Diagnostics Pressure Transmitter, Sensor Revision 7 or 8	λ_{SD}	λ_{SU}^7	λ_{DD}	λ_{DU}	SFF⁸
Coplanar Differential & Coplanar Gage	-	6	685	34	95%
Coplanar Absolute, In-line Gage, & In-Line Absolute	-	6	681	34	95%
Coplanar Differential & Coplanar Gage PATC	-	6	699	20	97%
Coplanar Absolute, In-line Gage, & In-Line Absolute PATC	-	6	695	20	97%
3051S Advanced Flowmeter based on 1195, 405, or 485 Primaries					
3051S Advanced HART Flowmeter Series ⁹ , Sensor sw rev 7 or 8	-	14	685	45	
Rosemount 3051S Advanced Level Transmitter: (w/o additional Seal)					
3051S Advanced HART Level Transmitter, Sensor sw rev 7 or 8	-	6	702	51	
3051S Advanced Transmitter with Remote Seals¹⁰					

⁷ It is important to realize that the No Effect failures are no longer included in the Safe Undetected failure category according to IEC 61508, ed2, 2010.

⁸SFF not required for devices certified using Route 2_H data. For information detailing the Route 2_H approach as defined by IEC 61508-2, see Technical Document entitled "Route 2_H SIL Verification for Rosemount Type B Transmitters with Type A Components".

⁹ Refer to ROS 13/04-008 R001 V1R0 for the Flowmeter FMEDA report for models that are excluded.

¹⁰ Refer to the Remote Seal (ROS 1105075 R001 V2R1) FMEDA report for the additional failure rates to use when using with attached Remote Seals, or use exSILentia.



5 Using the FMEDA Results

The following section(s) describe how to apply the results of the FMEDA.

5.1 Impulse line clogging

The transmitter can be connected to the process using impulse lines; depending on the application, the analysis needs to account for clogging of the impulse lines. The Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter failure rates that are displayed in section 4.4 are failure rates that reflect the situation where the transmitter is used in clean service. Clean service indicates that failure rates due to clogging of the impulse line are not counted. For applications other than clean service, the user must estimate the failure rate for the clogged impulse line and add this failure rate to the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter failure rates.

5.2 PFD_{AVG} calculation Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter

Using the failure rate data displayed in section 4.4, and the failure rate data for the associated element devices, an average the Probability of Failure on Demand (PFD_{avg}) calculation can be performed for the entire final element.

Probability of Failure on Demand (PFD_{avg}) calculation uses several parameters, many of which are determined by the particular application and the operational policies of each site. Some parameters are product specific and the responsibility of the manufacturer. Those manufacturer specific parameters are given in this third party report.

Probability of Failure on Demand (PFD_{avg}) calculation is the responsibility of the owner/operator of a process and is often delegated to the SIF designer. Product manufacturers can only provide a PFD_{avg} by making many assumptions about the application and operational policies of a site. Therefore, use of these numbers requires complete knowledge of the assumptions and a match with the actual application and site.

Probability of Failure on Demand (PFD_{avg}) calculation is best accomplished with *exida's* exSILentia tool. See Appendix D for a complete description of how to determine the Safety Integrity Level for an element. The mission time used for the calculation depends on the PFD_{avg} target and the useful life of the product. The failure rates and the proof test coverage for the element are required to perform the PFD_{avg} calculation. The proof test coverage for the suggested proof test and the dangerous failure rate after proof test for the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter are listed in Table 11.

5.3 *exida* Route 2_H Criteria

IEC 61508, ed2, 2010 describes the Route 2_H alternative to Route 1_H architectural constraints. The standard states:

"based on data collected in accordance with published standards (e.g., IEC 60300-3-2: or ISO 14224); and, be evaluated according to

- the amount of field feedback; and
- the exercise of **expert judgment**; and when needed
- the undertake of specific tests,

in order to estimate the average and the uncertainty level (e.g., the 90% confidence interval or the probability distribution) of each reliability parameter (e.g., failure rate) used in the calculations."



exida has interpreted this to mean not just a simple 90% confidence level in the uncertainty analysis, but a high confidence level in the entire data collection process. As IEC 61508, ed2, 2010 does not give detailed criteria for Route 2_H, *exida* has established the following:

1. field unit operational hours of 100,000,000 per each component; and
2. a device and all of its components have been installed in the field for one year or more; and
3. operational hours are counted only when the data collection process has been audited for correctness and completeness; and
4. failure definitions, especially "random" vs. "systematic" are checked by *exida*; and
5. every component used in an FMEDA meets the above criteria.

This set of requirements are chosen to assure high integrity failure data suitable for safety integrity verification.

6 Terms and Definitions

Automatic Diagnostics	Tests performed on line internally by the device or, if specified, externally by another device without manual intervention.
<i>exida</i> criteria	A conservative approach to arriving at failure rates suitable for use in hardware evaluations utilizing the 2 _H Route in IEC 61508-2.
FIT	Failure In Time (1×10^{-9} failures per hour)
FMEDA	Failure Mode Effect and Diagnostic Analysis
HFT	Hardware Fault Tolerance
Low demand mode	Mode, where the demand interval for operation made on a safety-related system is greater than twice the proof test interval.
PATC	Power Advisory of Failure on Demand
PFD _{AVG}	Average Probability of Failure on Demand
Severe service	Condition that exists when material through the valve has abrasive particles, as opposed to Clean Service where these particles are absent.
SFF	Safe Failure Fraction, summarizes the fraction of failures which lead to a safe state plus the fraction of failures which will be detected by automatic diagnostic measures and lead to a defined safety action.
SIF	Safety Instrumented Function
SIL	Safety Integrity Level
SIS	Safety Instrumented System – Implementation of one or more Safety Instrumented Functions. A SIS is composed of any combination of sensor(s), logic solver(s), and final element(s).
Type B element	“Complex” element (using complex components such as micro controllers or programmable logic); for details see 7.4.4.1.3 of IEC 61508-2



7 Status of the Document

7.1 Liability

exida prepares FMEDA reports based on methods advocated in International standards. Failure rates are obtained from a collection of industrial databases. *exida* accepts no liability whatsoever for the use of these numbers or for the correctness of the standards on which the general calculation methods are based.

Due to future potential changes in the standards, best available information and best practices, the current FMEDA results presented in this report may not be fully consistent with results that would be presented for the identical product at some future time. As a leader in the functional safety market place, *exida* is actively involved in evolving best practices prior to official release of updated standards so that our reports effectively anticipate any known changes. In addition, most changes are anticipated to be incremental in nature and results reported within the previous three-year period should be sufficient for current usage without significant question.

Most products also tend to undergo incremental changes over time. If an *exida* FMEDA has not been updated within the last three years and the exact results are critical to the SIL verification you may wish to contact the product vendor to verify the current validity of the results.

7.2 Releases

Version History: V2, R3: included cold temperature; updated template; recertification; TES 10/14/16
V2, R2: Modified Section 5 and created Appendix D; TES 8/22/14
V2, R1: Update to IEC 61508 2010 standard and 2_H, incorporated Rosemount comments; TES 7/9/14
V1, R4: Updated per Emerson Rosemount comments for cross product consistency; 6/16/13 Ted Stewart
V1, R3: Updated from V1, R2. Updated report to newest template, Customer asked us to leave the report to the 2000 standard; Ted Stewart – 6/16/13
V1, R2: Updated after fault injection testing
V1, R1: Updated per review, December 1, 2009
V1, R0: Updated based on Fault Injection results; November 25, 2009
V0, R1: Updated to reflect changes to default diagnostic; October 21, 2009
V0, R0: Draft; June 10, 2009

Current Author(s): Ted Stewart

Original Author(s): John Grebe and Ted Stewart

Review: V2, R3: William M. Goble (*exida*)

Release Status: RELEASED to Rosemount, Inc.



7.3 Future enhancements

At request of client.

7.4 Release signatures

A handwritten signature in black ink, appearing to read "William M. Goble", written over a solid black horizontal line.

Dr. William M. Goble, Principal Partner

A handwritten signature in black ink, appearing to read "Ted E. Stewart", written over a solid black horizontal line.

Ted E. Stewart, CFSP, Safety Engineer



Appendix A Lifetime of Critical Components

According to section 7.4.9.5 of IEC 61508-2, a useful lifetime, based on experience, should be assumed.

Although a constant failure rate is assumed by the probabilistic estimation method (see section 4.2.2) this only applies provided that the useful lifetime¹¹ of components is not exceeded. Beyond their useful lifetime the result of the probabilistic calculation method is therefore meaningless, as the probability of failure significantly increases with time. The useful lifetime is highly dependent on the subsystem itself and its operating conditions.

This assumption of a constant failure rate is based on the bathtub curve. Therefore, it is obvious that the PFD_{AVG} calculation is only valid for components that have this constant domain and that the validity of the calculation is limited to the useful lifetime of each component.

Table 7 shows which components are contributing to the dangerous undetected failure rate and therefore to the PFD_{AVG} calculation and what their estimated useful lifetime is.

Table 7 Useful lifetime of components contributing to dangerous undetected failure rate

Component	Useful Life
Capacitor (electrolytic) - Tantalum electrolytic, solid electrolyte	Approx. 500,000 hours

It is the responsibility of the end user to maintain and operate the Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter per manufacturer's instructions. Furthermore, regular inspection should show that all components are clean and free from damage.

As there are no aluminum electrolytic capacitors used, the limiting factors with regard to the useful lifetime of the system are the tantalum electrolytic capacitors. The tantalum electrolytic capacitors have an estimated useful lifetime of about 50 years.

¹¹ Useful lifetime is a reliability engineering term that describes the operational time interval where the failure rate of a device is relatively constant. It is not a term which covers product obsolescence, warranty, or other commercial issues.



Appendix B Proof Tests to Reveal Dangerous Undetected Faults

According to section 7.4.5.2 f) of IEC 61508-2 proof tests shall be undertaken to reveal dangerous faults which are undetected by automatic diagnostic tests. This means that it is necessary to specify how dangerous undetected faults which have been noted during the Failure Modes, Effects, and Diagnostic Analysis can be detected during proof testing.

B.1 Partial Proof Test – PATC Diagnostics Not Enabled

The partial proof test consists of an analog loop test. This test will detect ~41% of possible DU failures in the device when PATC is not utilized.

Table 8 Steps for Partial Proof Test –PATC Diagnostics Not Enabled

Step	Action
1.	Bypass the safety function and take appropriate action to avoid a false trip
2.	Use HART communications to retrieve any diagnostics and take appropriate action.
3.	Send a HART command to the transmitter to go to the high alarm current output and verify that the analog current reaches that value ¹² .
4.	Send a HART command to the transmitter to go to the low alarm current output and verify that the analog current reaches that value ¹³ .
5.	Perform a “reasonability check” on the pressure sensor reading and the sensor temperature sensor ¹⁴ .
6.	Remove the bypass and otherwise restore normal operation

¹² This tests for compliance voltage problems such as a low loop power supply voltage or increased wiring resistance. This also tests for other possible failures.

¹³ This tests for possible quiescent current related failures.

¹⁴ This tests for faults in the input multiplexer and A to D converter.



B.2 Comprehensive Proof Test – PATC Diagnostics Not Enabled

The comprehensive proof test consists of performing the same steps as the partial proof test but with a two-point calibration of the pressure and temperature sensors in place of the reasonability check of the sensors. This test will detect ~ 87% of possible DU failures in the device.

Table 9 Steps for Comprehensive Proof Test

Step	Action
1.	Bypass the safety function and take appropriate action to avoid a false trip
2.	Use HART communications to retrieve any diagnostics and take appropriate action.
3.	Send a HART command to the transmitter to go to the high alarm current output and verify that the analog current reaches that value ¹⁵ .
4.	Send a HART command to the transmitter to go to the low alarm current output and verify that the analog current reaches that value ¹⁶ .
5.	Perform a “reasonability check” on the pressure sensor reading and the sensor temperature sensor ¹⁷ .
6.	Perform a two-point calibration of the transmitter over the full working range.
7.	Remove the bypass and otherwise restore normal operation

¹⁵ This tests for compliance voltage problems such as a low loop power supply voltage or increased wiring resistance. This also tests for other possible failures.

¹⁶ This tests for possible quiescent current related failures.

¹⁷ This tests for faults in the input multiplexer and A to D converter.



B.3 Partial Proof Test – PATC Diagnostics Enabled

This proof test with the PATC diagnostics enabled will detect ~78% of DU failures in the device.

Table 10 Steps for Partial Proof Test –PATC Diagnostics Enabled

Step	Action
1.	Bypass the safety function and take appropriate action to avoid a false trip
2.	Use HART communications to retrieve any diagnostics and take appropriate action.
3.	Perform a “reasonability check” on the pressure sensor reading and the sensor temperature sensor ¹⁸
4.	Perform a two-point calibration of the transmitter over the full working range.
5.	Remove the bypass and otherwise restore normal operation

When the Power Advisory and Transmitter Power Consumption (PATC) diagnostics are enabled and alarm values configured, the testing functionality described in steps 3 and 4 of the partial and comprehensive proof test; (Table 8 and Table 9). This eliminates the need for the partial proof test, simplifies the comprehensive proof test, and thereby reduces the total proof test workload.

B.4 Proof Test Coverage

The Proof Test Coverage for the various product configurations is given in Table 11.

Table 11 Proof Test Coverage – Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter

Device	Partial	Comprehensive	PATC Enabled
Rosemount 3051S Advanced HART Diagnostics Pressure Transmitter	41%	87%	78%

¹⁸ This tests for faults in the input multiplexer and A to D converter.



Appendix C *exida* Environmental Profiles

Table 12 *exida* Environmental Profiles

<i>exida</i> Profile	1	2	3	4	5	6
Description (Electrical)	Cabinet mounted/ Climate Controlled	Low Power Field Mounted no self-heating	General Field Mounted self-heating	Subsea	Offshore	N/A
Description (Mechanical)	Cabinet mounted/ Climate Controlled	General Field Mounted	General Field Mounted	Subsea	Offshore	Process Wetted
IEC 60654-1 Profile	B2	C3 also applicable for D1	C3 also applicable for D1	N/A	C3 also applicable for D1	N/A
Average Ambient Temperature	30 C	25 C	25 C	5 C	25 C	25 C
Average Internal Temperature	60 C	30 C	45 C	5 C	45 C	Process Fluid Temp.
Daily Temperature Excursion (pk-pk)	5 C	25 C	25 C	0 C	25 C	N/A
Seasonal Temperature Excursion (winter average vs. summer average)	5 C	40 C	40 C	2 C	40 C	N/A
Exposed to Elements / Weather Conditions	No	Yes	Yes	Yes	Yes	Yes
Humidity¹⁹	0-95% Non-Condensing	0-100% Condensing	0-100% Condensing	0-100% Condensing	0-100% Condensing	N/A
Shock²⁰	10 g	15 g	15 g	15 g	15 g	N/A
Vibration²¹	2 g	3 g	3 g	3 g	3 g	N/A
Chemical Corrosion²²	G2	G3	G3	G3	G3	Compatible Material
Surge²³						
Line-Line	0.5 kV	0.5 kV	0.5 kV	0.5 kV	0.5 kV	N/A
Line-Ground	1 kV	1 kV	1 kV	1 kV	1 kV	
EMI Susceptibility²⁴						
80 MHz to 1.4 GHz	10 V/m	10 V/m	10 V/m	10 V/m	10 V/m	N/A
1.4 GHz to 2.0 GHz	3 V/m	3 V/m	3 V/m	3 V/m	3 V/m	
2.0GHz to 2.7 GHz	1 V/m	1 V/m	1 V/m	1 V/m	1 V/m	
ESD (Air)²⁵	6 kV	6 kV	6 kV	6 kV	6 kV	N/A

¹⁹ Humidity rating per IEC 60068-2-3

²⁰ Shock rating per IEC 60068-2-6

²¹ Vibration rating per IEC 60770-1

²² Chemical Corrosion rating per ISA 71.04

²³ Surge rating per IEC 61000-4-5

²⁴ EMI Susceptibility rating per IEC 6100-4-3

²⁵ ESD (Air) rating per IEC 61000-4-2



Appendix D Determining Safety Integrity Level

Three things must be checked when verifying that a given Safety Instrumented Function (SIF) design meets a Safety Integrity Level (SIL) [N5] and [N8].

These are:

- A. Systematic Capability or Prior Use Justification for each device meets the SIL level of the SIF;
- B. Architecture Constraints (minimum redundancy requirements) are met; and
- C. a PFD_{avg} calculation result is within the range of numbers given for the SIL level.

A. Systematic Capability (SC) is defined in IEC61508:2010. The SC rating is a measure of design quality based upon the methods and techniques used to design and development a product. All devices in a SIF must have a SC rating equal or greater than the SIL level of the SIF. For example, a SIF is designed to meet SIL 3 with three pressure transmitters in a 2oo3 voting scheme. The transmitters have an SC2 rating. The design does not meet SIL 3. Alternatively, IEC 61511 allows the end user to perform a "Prior Use" justification. The end user evaluates the equipment to a given SIL level, documents the evaluation and takes responsibility for the justification.

B. Architecture constraints require certain minimum levels of redundancy. Different tables show different levels of redundancy for each SIL level. A table is chosen and redundancy is incorporated into the design [N9].

C. Probability of Failure on Demand (PFD_{avg}) calculation uses several parameters, many of which are determined by the particular application and the operational policies of each site. Some parameters are product specific and the responsibility of the manufacturer. Those manufacturer specific parameters are given in this third party report.

A Probability of Failure on Demand (PFD_{avg}) calculation must be done based on a number of variables including:

1. Failure rates of each product in the design including failure modes and any diagnostic coverage from automatic diagnostics (an attribute of the product given by this FMEDA report);
2. Redundancy of devices including common cause failures (an attribute of the SIF design);
3. Proof Test Intervals (assignable by end user practices);
4. Mean Time to Restore (an attribute of end user practices);
5. Proof Test Effectiveness; (an attribute of the proof test method used by the end user with an example given by this report);
6. Mission Time (an attribute of end user practices);
7. Proof Testing with process online or shutdown (an attribute of end user practices);
8. Proof Test Duration (an attribute of end user practices); and
9. Operational/Maintenance Capability (an attribute of end user practices).

The product manufacturer is responsible for the first variable. Most manufacturers use the *exida* FMEDA technique which is based on over 100 billion hours of field failure data in the process industries to predict these failure rates as seen in this report. A system designer chooses the second variable. All other variables are the responsibility of the end user site. The exSILentia® SILVer™ software considers all these variables and provides an effective means to calculate PFD_{avg} for any given set of variables.

Simplified equations often account for only for first three variables. The equations published in IEC 61508-6, Annex B.3.2 [N1] cover only the first four variables. IEC61508-6 is only an informative portion of the standard and as such gives only concepts, examples and guidance based on the

idealistic assumptions stated. These assumptions often result in optimistic PFDavg calculations and have indicated SIL levels higher than reality. Therefore, idealistic equations should not be used for actual SIF design verification.

All the variables listed above are important. As an example consider a high level protection SIF. The proposed design has a single SIL 3 certified level transmitter, a SIL 3 certified safety logic solver, and a single remote actuated valve consisting of a certified solenoid valve, certified scotch yoke actuator and a certified ball valve.

Using exSILentia with the following variables selected to represent results from simplified equations:

- Mission Time = 5 years
- Proof Test Interval = 1 year for the sensor and final element, 5 years for the logic solver
- Proof Test Coverage = 100% (ideal and unrealistic but commonly assumed)
- Proof Test done with process offline

This results in a PFDavg of 6.82E-03 which meets SIL 2 with a risk reduction factor of 147. The subsystem PFDavg contributions are Sensor PFDavg = 5.55E-04, Logic Solver PFDavg = 9.55E-06, and Final Element PFDavg = 6.26E-03 (Figure 1).




Figure 1: exSILentia results for idealistic variables.

If the Proof Test Interval for the sensor and final element is increased in one year increments, the results are shown in Figure 2.




Figure 2 PFDavg versus Proof Test Interval.

If a set of realistic variables for the same SIF are entered into the exSILentia software including:

- Mission Time = 25 years
- Proof Test Interval = 1 year for the sensor and final element, 5 years for the logic solver
- Proof Test Coverage = 90% for the sensor and 70% for the final element
- Proof Test Duration = 2 hours with process online.
- MTTR = 48 hours
- Maintenance Capability = Medium for sensor and final element, Good for logic solver

with all other variables remaining the same, the PFDavg for the SIF equals 5.76E-02 which barely meets SIL 1. The subsystem PFDavg contributions are Sensor PFDavg = 2.77E-03, Logic Solver PFDavg = 1.14E-05, and Final Element PFDavg = 5.49E-02 (Figure 3).




Figure 3: exSILentia results with realistic variables

It is clear that PFDavg results can change an entire SIL level or more when all critical variables are not used.